

**Perth & Kinross Council  
Building Standards**



**Building (Scotland) Act 1959 & 1970  
List of Outstanding Section 13's  
(Notices relating to Dangerous Buildings)**

Reference Number	Address	Date Served	Description
DB/15/94	Old Inchtute Station Building, Inchtute	23/12/94	Remove or repair to make safe the stone mullions to the bay window that bounds on to land owned by British Rail.
DB/14/95	8-10 Inchaffrey Street, Perth	19/06/95	Remove to make safe the defective ground floor structure at the above address
DB/6/98	Sundial House, Sundial Cottage, Brae Street, Dunkeld	20/10/98	Demolish and rebuild so far as is necessary to make safe the defective wall, floor and roof at the Northeast face of the building
DB/7/99	Wash House, 34-36 Friar Street, Perth	10/03/99	Repair or take down to make safe brick chimney stack which forms rear wall of the washhouse. Repair the damaged section of brickwork on the North-most part of rear wall of the washhouse. Repair the guttering on front and rear elevations of the washhouse
DB/4/01	23-27 St Catherines Road, Perth	05/03/01	Replace or repair to make safe the defective lintel and stonework above the window over the flat known as Flat Number 11.
DB/7/01	170-180 High Street/5-7 Scott Street, Perth	10/04/01	Remove to make safe loose and spalling stonework to the elevations of the building facing Scott Street and High Street, Perth
DB/6/03	Former Chip Shop Mid Street Alyth	07/07/03	Remove so far as is necessary to make safe the loose slates, spalling stonework and unstable roof and chimney.
04/00001/DB	25-27 St Catherines Road Perth	09/01/04	Repair or demolish to make safe the defective chimney being the third most from the Southern end of the block
04/00002/DB	Auchtergaven & Moneydie Church Cairneyhill Road Bankfoot	27/02/04	Take down as far as is necessary to make safe and secure against entry the above fire damage building.
04/00016/DB	20 Ruthvenvale Terrace Auchterarder	15/07/04	Brickwork over the doorway to external store/cellar to be made safe by removal or by providing support
04/00017/DB	27-28 Ruthvenvale Terrace Auchterarder	16/07/04	Make Safe the balcony by repair or providing a means of support for access the balcony
05/00005/DB	59-63 East High Street, Crieff	22/02/05	Demolish, Secure or repair to make safe defective masonry and associated lintols to former outside toilets at East most Rear of building

