

**PERTH AND KINROSS COUNCIL**  
**Licensing Committee – 16 August 2012**  
**RENEWAL OF A SECOND HAND DEALERS LICENCE NO. SD96 – 3 YEARS**  
**Report by Head of Legal Services**

<b>Name and Address :</b>	John Cameron 93-95 Canal Street Perth  Age: 57
<b>6 Month Decision Date:</b>	25 December 2012
<b>Reason for Report:</b>	Tayside Fire & Rescue have lodged an objection to this application (see attached copy email dated 3 July 2012 together with copy letter to applicant).
<b>Background Information:</b>	None

**Contact Officer: Shona Douglas Ext 75154**



[REDACTED]  
**Sent:** 03 July 2012 11:56

**To:** Nicola Storrar

**Subject:** RE: SD96 - J Cameron

Nikki, I would object to this application until he provides evidence that he has reinstated the ceiling between him and the Green Room (Formerly Mucky Mulligans) on the upper floor to the required 60 minute fire resistant standard, as previously requested of him last year.

RD/MK

R. Davidson, District Enforcement Officer



15<sup>th</sup> November 2012

Mr John Cameron  
93-95 Canal Street  
Perth  
PH2 0AU


Dear Sir,

**Fire Separation**

Following discussion with the new Licensee of Mucky Mulligans and the subsequent discussion with yourself on 15<sup>th</sup> November 2011, it was discussed that the ceiling within your ground floor storage area should provide 60 minutes (medium) fire separation between your store and the upper floor of the building occupied by Mucky Mulligans.

This remedial work should be carried out as soon as possible.

Yours faithfully



R. Davidson  
District Enforcement Officer